


# PL-PANEL-M2000-BLR

## Internal Electrical Wiring Diagram



## Field Wiring Details

Terminal	Function	Ratings	Wiring Details	Terminal	Function	Ratings	Wiring Details
	GROUND	N/A	Use Copper Conductors Only, 60°C/140°F, Maximum Torque Conductor Mounting: 0.5Nm	15	24 VAC Supply	24 VAC, 6.7 VA	Use Copper Conductors Only, 60°C/140°F, Maximum Torque Conductor Mounting: 0.5Nm
1	Power Supply Input Common	N/A	Use Copper Conductors Only, 60°C/140°F, Maximum Torque Conductor Mounting: 0.5Nm	16	N/A	N/A	N/A
2	Power Supply Input 24 VAC	24 VAC, 3 A, 60Hz	Use Copper Conductors Only, 60°C/140°F, Maximum Torque Conductor Mounting: 0.5Nm	17	Dry Contact to Disable Boiler Call	N/A	Use Copper Conductors Only, 60°C/140°F, Maximum Torque Conductor Mounting: 0.5Nm
3	Boiler Stage 1 Output	24 VAC, 300 mA	Use Copper Conductors Only, 60°C/140°F, Maximum Torque Conductor Mounting: 0.5Nm	18	Dry Contact for Max Heat Setpoint	N/A	Use Copper Conductors Only, 60°C/140°F, Maximum Torque Conductor Mounting: 0.5Nm
4	Boiler Stage 2 Output	24 VAC, 300 mA	Use Copper Conductors Only, 60°C/140°F, Maximum Torque Conductor Mounting: 0.5Nm	19	Dry Contact for Proof of Pump 2	N/A	Use Copper Conductors Only, 60°C/140°F, Maximum Torque Conductor Mounting: 0.5Nm
5	Boiler Stage 3 Output	24 VAC, 300 mA	Use Copper Conductors Only, 60°C/140°F, Maximum Torque Conductor Mounting: 0.5Nm	20	Dry Contact for Proof of Pump 1	N/A	Use Copper Conductors Only, 60°C/140°F, Maximum Torque Conductor Mounting: 0.5Nm
6	Boiler Stage 4 Output	24 VAC, 300 mA	Use Copper Conductors Only, 60°C/140°F, Maximum Torque Conductor Mounting: 0.5Nm	21	Return Water Temperature Thermistor (10K Type 3)	N/A	Use Copper Conductors Only, 60°C/140°F, Maximum Torque Conductor Mounting: 0.5Nm
7	Pump 1 Output	24 VAC, 300 mA	Use Copper Conductors Only, 60°C/140°F, Maximum Torque Conductor Mounting: 0.5Nm	22	Supply Water Temperature Thermistor (10K Type 3)	N/A	Use Copper Conductors Only, 60°C/140°F, Maximum Torque Conductor Mounting: 0.5Nm
8	Pump 2 Output	0-10 VDC, 40 mA	Use Copper Conductors Only, 60°C/140°F, Maximum Torque Conductor Mounting: 0.5Nm	23	Outside Air Temperature Thermistor (10K Type 3)	N/A	Use Copper Conductors Only, 60°C/140°F, Maximum Torque Conductor Mounting: 0.5Nm
9	Modulating Boiler Output	0-10 VDC, 40 mA	Use Copper Conductors Only, 60°C/140°F, Maximum Torque Conductor Mounting: 0.5Nm	+	M2000 RS485 INT A (+)	N/A	Use Copper Conductors Only, 60°C/140°F, Maximum Torque Conductor Mounting: 0.5Nm
10	24 VAC Supply	24 VAC, 5 VA	Use Copper Conductors Only, 60°C/140°F, Maximum Torque Conductor Mounting: 0.5Nm	-	M2000 RS485 INT B (-)	N/A	Use Copper Conductors Only, 60°C/140°F, Maximum Torque Conductor Mounting: 0.5Nm
11	Valve or Backup Modulating Boiler	0-10 VDC, 40 mA	Use Copper Conductors Only, 60°C/140°F, Maximum Torque Conductor Mounting: 0.5Nm	A	M2000 RS485 NET A (+)	N/A	Use Copper Conductors Only, 60°C/140°F, Maximum Torque Conductor Mounting: 0.5Nm
12	24 VAC Supply	24 VAC, 5 VA	Use Copper Conductors Only, 60°C/140°F, Maximum Torque Conductor Mounting: 0.5Nm	B	M2000 RS485 NET B (-)	N/A	Use Copper Conductors Only, 60°C/140°F, Maximum Torque Conductor Mounting: 0.5Nm
13	24 VAC supply	24 VAC, 0.03 A	Use Copper Conductors Only, 60°C/140°F, Maximum Torque Conductor Mounting: 0.5Nm	C	COMMON	N/A	Use Copper Conductors Only, 60°C/140°F, Maximum Torque Conductor Mounting: 0.5Nm
14	N/A	N/A	N/A				

This device complies with Part 15 of the FCC Rules. Operation is subject to the following two conditions: (1) this device may not cause harmful interference, and (2) this device must accept any interference received, including interference that may cause undesired operation.

