



Datasheet

Digital Sensor (PL-T1000)

Description

The ProLon T1000 digital sensor is designed to work with a variety of ProLon controllers, to which it transmits information such as the ambient zone temperature, heating and cooling setpoints, occupancy override status and other valuable parameters. The T1000 also provides the user with an access point to view and configure any parameter of the connected controller through a very intuitive onscreen menu system. The T1000 has a circular touchpad, a backlit graphical LCD and an auxiliary analog input, useful for an additional temperature reading.

Features

- 10KΩ Type 3 NTC thermistor 1% precision
- Circular capacitive touchpad and graphical display, which allow simple and intuitive control
- Designed to work with various ProLon C1000 and VC2000 series controllers, sending them zone temperature, set points and other configuration parameters
- Easy wiring with numbered screw type terminal block or RJ45 modular jack
- Input for auxiliary temperature sensor: Room temperature (average or remote) or slab temperature (for radiant floor applications)
- Circular touchpad and curved features offer a modern look. Other colors available!

Technical Specifications

Supply: 24 VAC ±10%, 50/60 Hz, Class 2

Power: 5 VA (max)

Inputs: 1 analog input (Thermistor 10K type 3), 10 bit resolution

Outputs: None

Screen: LCD 80x130 pixels with backlighting

Interface: Circular capacitive touchpad

Sound: Audible feedback during user interactions

Microprocessor: Atmel 32 bits, 60 MHz, 256KB FLASH memory

Connection: Screw type terminal blocks (16 AWG max) and RJ45 modular jack

Dimensions: 3.23" x 4.96" (82 mm x 126 mm)

Weight: 0.22 lb (0.1 kg)

Environment: 32-122 °F (0-50 °C)

Mounting: Standard electrical box 2" x 4"

Certification: FCC part 15: 2012 class B

Compliance

- FCC Compliant to CFR47, Part 15, Subpart B, Class B
- Industry Canada (IC) Compliant to ICES-003, Issue 5: CAN ICES-3 (B)/NMB-3(B)
- RoHS Directive (2002/95/EC)

This device complies with Part 15 of the FCC Rules. Operation is subject to the following two conditions: (1) this device may not cause harmful interference, and (2) this device must accept any interference received, including interference that may cause undesired operation.

Caution: Any changes or modifications not approved by ProLon can void the user's authority to operate the equipment.

Note: This equipment has been tested and found to comply with the limits for a Class B digital device, pursuant to part 15 of the FCC Rules. These limits are designed to provide reasonable protection against harmful interference in a residential installation. This equipment generates, uses and can radiate radio

frequency energy and, if not installed and used in accordance with the instructions, may cause harmful interference to radio communications. However, there is no guarantee that interference will not occur in a particular installation. If this equipment does cause harmful interference to radio or television reception, which can be determined by turning the equipment off and on, the user is encouraged to try to correct the interference by one or more of the following measures:

- Reorient or relocate the receiving antenna.
- Increase the separation between the equipment and receiver.
- Connect the equipment into an outlet on a circuit different from that to which the receiver is connected.
- Consult the dealer or an experienced radio/TV technician for help.

This Class (B) digital apparatus meets all the requirements of the Canadian Interference-Causing Equipment regulations.

Phone 450-973-5100 | Toll Free 1-877-977-6566